

Retail Food Inspection Report

Floyd County Health Department

Telephone (812) 948-4726

Establishment Name LEGENDS CAFE	Telephone Number Est 812-913-3431 Own	Date of Inspection 07/14/2021	ID#
Address 2607 CHARLESTOWN RD, NEW ALBANY IN 47150			
Owner	Purpose <u> </u> Routine <u> </u> Follow-up <u> </u> Complaint <u> </u> Pre-Operational <u> </u> Temporary <u> </u> HACCP <u> X </u> Other (list) WALK THROUGH	Follow Up	Released 07/14/2021
Owner's Address ,			
Person in Charge JEREMY CLARY			
Responsible Person's Email		Menu Type 1 <u> X </u> 2 <u> </u> 3 <u> </u> 4 <u> </u> 5 <u> </u>	
Certified Food Handler			

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRATIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
218		X		Observed 3 door, standing freezer to not be operational.	Before opening for all v
232		X		Observed blocks of wood under bar's 4 comp sink. Wood should be painted or sealed.	
284		X		Observed no hot water throughout building.	
307		X		Observed the hood system had not been inspected or approved.	
324		X		Observed leak around hot water handle on handwashing sink near warewash.	
347		X		Observed no hand towels at handwashing sink in kitchen.	
404		X		Observed damaged and missing tile coving on right side when entering the kitchen. Observed missing coving on wall behind equipment in kitchen.	
411		X		Observed light bulb out in walk in cooler.	
420		X		Observed power tools in kitchen.	
430		X		Observed damaged drywall around back door. Observed damaged or missing drain covers through out kitchen.	
433		X		Observed mops not hung to dry. Install hooks or method to hang mops.	

Summary of Violations C 0 NC 11 R 0

Received by (name and title printed):

Inspected by (name and title printed):

Thomas Snider CFS

Received by (signature):

Inspected by (signature):

Thomas Snider

cc:

cc:

cc: